

# **Rancho Murieta CSD**

## **AUGMENTATION WELL PROJECT**

### RFI's Answered:

- 1) Is bonding going to be required?
  - Yes it is. See General Specifications attached to the bid packet; G1-07, G2-08, G3-05, G4-15 and all applicable sections.
- 2) What bond form should we use?
  - The one provided in the General Specifications, section FO-III & FO-IV & pg.140 & 142 of the bid packet pdf.
- 3) Will water be made available?
  - Yes. A District hydrant meter will be set up on a fire hydrant for use by the awarded contractor.
- 4) What is the Prevailing Wage determination?
  - See the <http://www.dir.ca.gov/OPRL/2017-1/PWD/index.htm> in Sacramento County for Water Well Driller.
- 5) Bid item 5 is it not 24" conductor, item 6 should be 300' as conductor drilling accounts go first 50', at pre con stated cutting could 've spread on site, Spec's say remove from site 1.06B., can you clarify. Restore area pre work condition, so you want pad removed?
  - Bid for information presented.
    - 1) 50 feet of conductor off the borehole pay item – footage amounts are just estimates but bid as presented; 2) even though the owner may allow the cuttings to stay on site; please include in the cost for the removal of cuttings and muds; 3) The all-weather pad should be in the bid. The removal of the pad is not necessary