



---

## State Water Resources Control Board

### Division of Drinking Water

January 31, 2024

PWS No. 3410005

Michael T. Fritschi, P.E.  
Director of Operations  
Rancho Murieta Community Services District  
15160 Jackson Road  
Rancho Murieta, CA 95683

### **RANCHO MURIETA COMMUNITY SERVICES DISTRICT WATER SYSTEM (PWS NO. 3410005)**

### **LEAD AND COPPER MONITORING**

### **NOTICE OF VIOLATION No. 01-09-24N-002**

The State Water Resources Control Board, Division of Drinking Water (Division) recently completed a review of the Rancho Murieta Community Services District (Water System) public water system (PWS No. 3410005) water quality monitoring results.

The Water System is required to complete tap sampling in accordance with Chapter 17.5, Division 4, Title 22 of the California Code of Regulations (CCR) to meet the United States Environmental Protection Agency (US EPA) Lead and Copper Rule (LCR) tap sampling requirements.

According to the submitted records, the Water System is on a reduced monitoring schedule. The last round of tap sampling was completed in 2023; however, the Water System failed to complete the required tap sampling during the months of June, July, August, or September as required by Chapter 17.5, Division 4, Title 22 of the CCR. Please review the Water System Operations and Maintenance Plan and/or water quality monitoring plan(s) to ensure all mandated water quality monitoring has been incorporated.

The Water System shall complete one round of LCR tap sampling according to Chapter 17.5, Division 4, Title 22 of the CCR in **2024** (during the months of June, July, August, or September). Thereafter, and upon review of the submitted analyses results, the Water System may return to its current monitoring schedule of reduced tap sampling schedule once every three years beginning **2026** (sampling to be conducted in 2026). Water System shall note this notice of violation in the 2024 Consumer Confidence Report (for water year 2023), in accordance with Section 64481(g), Article 20, Chapter 15, Division 4, Title 22 of the CCR.

---

E. JOAQUIN ESQUIVEL, CHAIR | ERIC OPPENHEIMER, EXECUTIVE DIRECTOR

Michael T. Fritschi, P.E.  
Director of Operations  
Rancho Murieta CSD

- 2 -

January 31, 2024  
PWS No. 3410005  
Notice of Violation No. 01-09-24N-002

All analytical results shall be submitted electronically to the State Water Board via an approved method no later than the 10<sup>th</sup> day of the month following completion of the analyses.

Failure to monitor the required LCR tap sampling could result in a citation with fines from this office and/or US EPA.

If you have any questions, or if we can be of any assistance, please do not hesitate to contact Kooshlar Vaghefi by email at: [kooshlar.vaghefi@waterboards.ca.gov](mailto:kooshlar.vaghefi@waterboards.ca.gov) or by telephone at (916) 327-9848.

Sincerely,



Austin Peterson, P.E.  
Sacramento District Engineer  
Division of Drinking Water  
STATE WATER RESOURCES CONTROL BOARD

cc. Kooshlar Vaghefi – Water Resource Control Engineer, DDW, SWRCB